Organisation Banner PADAM INTERIORS	NEAR MISS REPORT FORM	Ref. No.	T/APR/NMR/26/00002
		Issue Date:	13-Feb-2026
		Rev No.	1

Project Name: Aparna Constructions **Report No:** T/APR/NMR/26/00002

Vendor Name: Rajkumar Pativada

Location: 16 july 2025

Date: 13-Feb-2026

Time Accident: 07:44:06 PM

Near miss Subject: Ladder Slippage in Main Warehouse

Near miss Description: A technician was ascending a 10ft ladder when the base slipped approximately 4 inches. The technician maintained their grip and did not fall. No injuries occurred.

Corrective actions and recommendations: Immediate inspection of all ladder rubber feet. Purchase of "ladder stoppers" for polished floor areas.

Analysis

Unsafe Actions: Using a ladder without a second person to "spot" or secure the base.

Unsafe Condition: Polished epoxy flooring with high slip potential.

Human Error: Overconfidence in equipment stability.

Machinical Failure: Worn-out anti-skid rubber pads on the ladder feet.

E. Comments: Incident occurred at 09:00 AM during routine lighting maintenance.

Prepared by Name:	Prepared by Name:	Prepared by Name:
Signature:	Signature:	Signature: