

Inspection Report - Fire Extinguisher Inspection Checklist (Inspection UID - I/MHC/GRR/FEI/26/00015)

Inspection Information

Inspection Type	Fire Extinguisher Inspection Checklist	Inspection Status	Approved
Site Name	Alanreed	Created on	06-Mar-2026 11:44:54 AM
Asset	Fire extinguisher co2	Non Oqsha Assets	
Next Inspection Date	06-Apr-2026 11:44:54 AM	Next Inspection Overdue Days	0

Sections

Inspection checks

Company name: My Home Constructions Private Limited	Contractor name: Nakka Phanindra Kumar EHS
--	---

Attachments
Image

Equipment Status

Equipment Status at Site: In Site	Equipment Usage Status: In Usage
--	---

Check Points

Is fire extinguisher being physically in good condition, including there is no signs of damage, corrosion or tempering?: Yes	Is temper seal is intact with pin available without any damage and not tempered and nothing was used in place of the pin?: Yes	Is discharge hose/Nozzle was in good condition without clogged, crack or broken. And is it free from leakage?: Yes	Is handle of fire extinguisher was intact and firm?: Yes
Is label, type of fire extinguisher and instruction are available and easy to read?: Yes	Is fire extinguisher was fully charged and pressure gauge is in green position?: Yes	Is fire extinguisher has mounted or placed in free of obstacles place and visible location? (above 40lbs should mounted 3.5feet level only): Yes	Is fire extinguisher having valid inspection and maintenance tag? If not so, need to replace that fire extinguisher.: Yes

Signatures

Inspected by: Nakka Phanindra Kumar EHS at 06-Mar-2026 11:44 AM.	Checked by: Uma Mahesh Akki at 3/12/2026 5:05:57 PM.	Verified by: Srikanth Anumula MHC at 3/12/2026 5:50:39 PM.	Approved by: sravan kumar pakki at 3/12/2026 6:03:50 PM.
---	---	---	---

Inspection History

Created On	Created By	Comment	Attachments
12-Mar-2026 06:03:50 PM	Rena Kay	Status has been updated to 'Approve'	
12-Mar-2026 06:03:49 PM	Rena Kay	sravan kumar pakki has Approved.	
12-Mar-2026 05:50:39 PM	Racheal Piatt	Status has been updated to 'Verify'	
12-Mar-2026 05:50:39 PM	Racheal Piatt	Inspection has been assigned to sravan kumar pakki at the Approved by stage.	
12-Mar-2026 05:50:38 PM	Racheal Piatt	Srikanth Anumula MHC has Verified.	
12-Mar-2026 05:05:57 PM	Owens Strauss	Inspection has been assigned to Srikanth Anumula MHC at the Verified by stage.	
12-Mar-2026 05:05:57 PM	Owens Strauss	Uma Mahesh Akki has Checked.	
12-Mar-2026 05:05:57 PM	Owens Strauss	Status has been updated to 'Check'	
06-Mar-2026 11:44:59 AM	Caroline Su	A new record was created: Site set to 'Grava Residences' Asset Type set to 'Safety equipment' Inspection Type set to 'Fire Extinguisher Inspection Checklist' Status set to 'Inspection requested'	
06-Mar-2026 11:44:59 AM	Caroline Su	Inspection has been assigned to Uma Mahesh Akki at the Checked by stage.	