

Safety Alert Report

Organisation	Kura Oncology Inc.
Safety Alert UID	T/TRS/UCC/26/00041
Status	Open
DueDate	28-Mar-2026
Severity	Moderate
Site	Morgan's Point Resort
Area	Pattern Shop Section
User Type	Employee
Department	Electrical
Reported By	Gary Bhatia
Mobile Number	+91 2000005487
Others Involved	NA
Category	Unsafe Condition
Description	Electrical wires being used without appropriate plug top. Hazard/ Risk - Electrical Shock. Responsible department - Maintenance Location - Pattern shop Corrective action - Industrial Plug top required.
Safety Alert Image(s)	<input type="text"/>
Safety Alert Video(s)	NA
Safety Alert Audio(s)	NA
Safety Alert File(s)	NA
Created	23-Mar-2026 12:04:14 PM
Modified	23-Mar-2026 12:04:14 PM
Investigation Checklist	NA
Assigned To	Delta Crump
Resolved On	NA
Safety Alert History	<p>23-Mar-2026 12:04:14 PM - Gary Bhatia: A new record was created: Uid set to 'T/TRS/UCC/26/00041' Site set to 'Foundry-I' Reported By set to 'Saikat Kar' Category set to 'Unsafe Condition' Department set to 'Electrical' Assigned To set to 'Subrata Santra' Severity set to 'Moderate' Due Date set to '28-Mar-2026' Area set to 'Pattern Shop Section'</p> <p>23-Mar-2026 12:04:15 PM - Gary Bhatia: Uploaded 1 Attachment(s).</p>

This is a computer generated report. For queries please mail to contact@oqsha.com