

Organisation Logo

Work Permit Report - (Work Permit UID - WP/APR/abd/HWW/26/00001)

Work Permit Information

Work Permit UID	WP/APR/abd/HWW/26/00001	Category Name	Electrical Work - Titagargh
Description		Status	Draft
Site Name	Aparna New Site	Department Name	am
Location		Initiated By	Sayan Mondal
Start Date & Time	05-Feb-2026 02:00:00 PM	End Date & Time	05-Feb-2026 10:00:00 PM
Created On	05-Feb-2026 12:02:56 PM	Due Date	05-Feb-2026 12:00:00 AM
Contractor	NA	Shift	NA

Sections

1. Hazards Identified			
<input type="checkbox"/> Presence of Toxic Gas Fumes	<input type="checkbox"/> Sharp Edges	<input type="checkbox"/> Poor Lighting	<input type="checkbox"/> Height Work (Above 2 Meter.)
<input type="checkbox"/> Work near Over Head Electrical Line	<input type="checkbox"/> Combustible Materials Nearby	<input type="checkbox"/> Trip Hazard	<input type="checkbox"/> Static Electricity
<input type="checkbox"/> Work on Fragile Roofs	<input type="checkbox"/> Improper Access to reach height	<input type="checkbox"/> Work near sharp edges in ground level	<input type="checkbox"/> Slip Hazard
<input type="checkbox"/> Steam	<input type="checkbox"/> Work on Standing Ladder	<input type="checkbox"/> Work on Moving Machinery	<input type="checkbox"/> Confined Space
<input type="checkbox"/> Excavation Collapse	<input type="checkbox"/> Oil Spillage Observed	<input type="checkbox"/> Work on Scaffolding	<input type="checkbox"/> Unguarded Opening
<input type="checkbox"/> Mechanical / Electrical Sparks	<input type="checkbox"/> Noise / Vibration	<input type="checkbox"/> Pressurized Line	Other Hazards::
2. Control Measures			

If any of the above criteria required is not met, then do not issue the work permit.:

YES	NO	NA	Check Points for the Initiator
			Is all hand tools & equipment's inspected & tag provided?
			If Work is to be carried on fragile roof then life line provided to prevent a fall
			Use of full body harness with life line and provision available to anchor life line and lanyard of harness
			Proper access / Ladder is to be provided to reach at work place and use safety belt with life line
			Proper staging, platform and handrails provided (Top rail, Mid rail & Toe guard) provided
			Precaution should be taken to avoid falling of tools from height
			Caution board indicating "MEN AT WORK" displayed and barricading provided
			Disconnected any electrical equipment with in proximity of working at height before startup of work
			Persons / Certified rigger medically fit and sufficiently trained
			Persons / Certified rigger medically fit and sufficiently trained
			If scaffold used, Checked the condition of scaffolding & found satisfactory
			Any other source of potential hazard identified (Fire, Explosion, Fumes, Electrical leakages, Slippery surface)
			For electrical height work, is FRP ladder available
			Is stand by person available to hold the ladder Name: _____
			Is ladder placing in 75 deg angle?
			Is ladder inspected, physical condition is good & certified with green tag?
			Is nearby vehicle movement are eliminated & barricaded?
			For roof work, Is Job Safety Analysis was conducted & approved by Central HSE Head? – Mandatory for Roof Work
			Stop the work during rain, heavy wind & any other abnormal environment

3. Safety Equipment Requirement & PPE to be used

<input type="checkbox"/> Safety Glasses	<input type="checkbox"/> Nose Mask / Respirators	<input type="checkbox"/> Safety Harness / Lifeline	<input type="checkbox"/> Fire Extinguisher No.
<input type="checkbox"/> Safety Shoes	<input type="checkbox"/> Hand Gloves	<input type="checkbox"/> Ear Plug/ Muff	<input type="checkbox"/> Scaffolds & Ladders
<input type="checkbox"/> Locks/ tags No. _____	<input type="checkbox"/> Barricades & Warning Signs	<input type="checkbox"/> Face Shield / Welding Goggle	<input type="checkbox"/> Helmet
<input type="checkbox"/> Forced Ventilation	<input type="checkbox"/> Apron	<input type="checkbox"/> Any Other:	LOTO Tag LOTO Tag Reference No.:Reference No.:

Approvers

{ApproversDetails}

History

Created On	Created By	Comment	Attachments
------------	------------	---------	-------------

05-Feb-2026 12:02:56 PM	Sayan Mondal	A new record was created: Site Name set to 'Aparna New Site' Department set to 'am' Type Of Permit set to 'Height Work' Name Of Requestor set to 'Sayan Mondal' Shift set to 'Second Shift' Work Permit Date Start set to '05-Feb-2026' Work Permit Date End set to '05-Feb-2026' Work Permit Time Start set to '02:00 PM' Work Permit Time End set to '10:00 PM' Is Manual Ptw set to 'False' Status set to 'Draft'	NA
----------------------------	--------------	--	----